

Certificate of Assessment

NK6074

No. 1332

"Copyright CSIRO 2009 ©"
Copying or alteration of this report
without written authorisation from CSIRO is forbidden.

This is to certify that the specimen described below was tested by the CSIRO Division of Materials Science and Engineering in accordance with Australian/ New Zealand Standard 3837, Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter, 1998, at 50 kW/m², on behalf of:

Tekform Marketing Pty. Limited
Unit 1, 41-43 Whyalla Place
PRESTONS NSW
AUSTRALIA

A full description of the test specimen and the complete test results are detailed in the Division's sponsored investigation report numbered FNK 9617.

SAMPLE

IDENTIFICATION: Duropal High Pressure Laminate

DESCRIPTION OF SAMPLE:

The sponsor described the tested specimen as high-pressure kraft paper laminate.

Nominal thickness: 0.8 mm

Nominal mass: 1030 g/m²

Colours: Virginia Bronze TR; Glacial Storm MS; Pastel Grey VV;
Taurus Sand HS; Natural Balearic Oak RV; Ruby Red CT;
Dark Oak RU

SAMPLE


CLASSIFICATION: Group Number: Group 1
(In accordance with Specification A2.4 of the Building Code of Australia.)

Average specific extinction area: 155.8 m²/kg
(Refer to Specification C1.10a section 3(c) of the Building Code of Australia.)


Testing Officer: Russell Collins

Date of Test: 1 December 2009

Issued on the 4th day of December 2009 without alterations or additions.



Garry E Collins
Manager, Fire Testing and Assessments



CSIRO

CSIRO Materials Science and Engineering
14 Julius Avenue, Riverside Corporate Park, North Ryde NSW 2113 AUSTRALIA
Telephone: 61 2 9490 5444 Facsimile: 61 2 9490 5555